



General Manager, Nuclear Power Project
Hitachi Europe Ltd.
(Senior Licensing Manager for UK ABWR GDA,
Assigned by Hitachi-GE Nuclear Energy Ltd.)
6th Floor, Capital House
25 Chapel Street
London
NW1 5DH

GSW Rose Court
2 Southwark Bridge
London SE1 9HS

Telephone:
Email:

Our Reference: 2017/218439
Unique Number: REG-HGNE-0190N

7 June 2017

Closure of Regulatory Observation - RO-ABWR-0031 – SSLC and Support System Architecture

I refer to Regulatory Observation RO-ABWR-0031 issued on 1 December 2014.

I am writing to confirm that you have:

- Reviewed and assigned adequate Category to the safety functions which are controlled by the Class 1 Safety System and Logic Control System;
- Reviewed and assigned adequate Categories to the safety functions which are controlled by the independent Safety Auxiliary Control System;
- Provided documentation that details the safety functions and their Categories and Safety Classification of Structures, System and Components;
- Provided documentation that details the design changes to ensure these safety functions would meet the safety expectation;
- Provided documentation to justify the adequacy of the design for the Category A safety functions which do not follow the UK relevant good practice.

On this basis, ONR confirms closure of Regulatory Observation RO-ABWR-0031.

A copy of this letter will be published on the ONR website in due course.

Yours sincerely